

williams&works

engineers | surveyors | planners

March 11, 2022

**Lincoln Charter Township
SANITARY SEWER CLOSED CIRCUIT TELEVISION (CCTV) INSPECTION – 2022
ADDENDUM No. 2**

Notice to All Prospective Bidders


This Addendum is issued in accordance with SECTION 00 20 00 - INSTRUCTIONS TO BIDDERS, and is hereby incorporated into the Contract Documents. The CONTRACTOR is reminded to acknowledge receipt of this Addendum in SECTION 00 42 00 - PROPOSAL.

Responses to Questions

1. *Will the owner award the contract if the Apparent Low Bidder's amount is over the Engineer's Estimate?* - The Engineer's Estimate is provided to assist Bidders in determining their bonding amount. Please refer to ARTICLE 13 – AWARD OF CONTRACTS in Section 00 20 00 – INSTRUCTIONS TO BIDDERS.
2. *There is wording about voice recording on the CCTV videos, this feature is not common amongst CCTV contracts, will this truly be required?* – Audio comments will be encouraged, but not required, where it may help to explain a specific observation in addition to the required written reporting data.
3. *Will squeegeeing the line be required for every diameter of Sanitary Sewer on this project?* – No. Squeegeeing would only be required if necessary to confirm adequate cleaning of the pipe that could not be confirmed by the video inspections and would be considered incidental to the other pay items, not paid for separately.
4. *Does the owner have a list of firms that they can share that would be available for testing the waste/debris removed from the Sanitary sewer after dumping? Is this service performed by the personnel at the dump site?* There are several testing firms in the West Michigan area that can perform this service, but the Owner does not have a specific list to share. The Orchard Hill Landfill does not provide testing services.

Respectfully submitted,

Williams & Works



David Austin, P.E.

cc: Planholders of Record